


**CONDENSING UNIT ROOF MOUNTING DETAIL - SINGLE UNIT (MAX 100kg)**

1:5



**CONDENSING UNIT ROOF MOUNTING DETAIL - MULTIPLE UNITS & SINGLE UNITS (100kg - 200kg)**

1:5

NOTE:

- CONDENSATE WASTE TO MEET EPA GUIDELINES.
- ISOLATORS TO BE MOUNTED ADJACENT UNITS ON UPSTANDS.
- ALL STEEL SUPPORT FRAME TO BE GALVANISED
- SEISMIC RESTRAINT TO AS 1170.4 OR TO ENGINEER'S SPECIFICATIONS



**Government of South Australia**  
 Department of Planning,  
 Transport and Infrastructure

CONTRACT NAME  
 PROJECT NAME

CONTRACT NO.  
 XXXX-A-20XX

DRAWN BY  
 pd 04/14

DPTI ASSET NO.  
 DPTI STANDARDS

SCALE AND SHEET SIZE  
 As Shown@A4

DRAWING NO.

REVISION

G-41

© COPYRIGHT - GOVERNMENT OF SOUTH AUSTRALIA - DPTI  
 SETTING OUT OF THE WORK IS THE RESPONSIBILITY OF THE CONTRACTOR  
 ALL DIMENSIONS TO BE VERIFIED ON SITE  
 DISCREPANCIES TO BE REPORTED IMMEDIATELY TO THE SUPERINTENDENT  
 THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER CONTRACT DOCUMENTS

DRAWING TITLE  
**ROOF MOUNTED PLANT DETAIL**  
**MECHANICAL, HYDRAULIC AND ELECTRICAL**